

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. memo/school/01

Dated: 22/07/2023

It is certified that an inspection team headed by Mr. Sumit Srivastava (J.E.) & team
(Name of Officers with designation) from U.P. Jal Nigam (Rural), Jaunpur
(Name of Department/ Office) inspected the Mount Litera Zee School, Jaunpur
(Name & Address of the school) on 21/07/23 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 01 year



Signature with Seal: [Signature]

Name : Sumit Srivastava

Designation : Senior Eng.

Assistant Engineer of
the Govt. Public Health Department (PHED)/
Authorised officer of the Local Body

Name & Address of the Office / Department :

To
Principal
Mount Litera Zee School
Fatehganj, Jaunpur

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

[Signature]
अधिसासी अभियन्ता
खण्ड कार्यालय
उत्तर प्रदेश जल निगम (ग्रामीण)
जौनपुर



Analysis Report District Jaunpur

Rept No	Date	Page No			
Customer Details					
Office Name and Address	Mount Litera Zee School, Allahabad Road Fatehganj Jaunpur Pin-222132				
Ref Letter No & Date	NA				
Basic details of sample					
District	Jaunpur	Block			
Gram Panchayat		Village			
Habitation		Location	Fatehganj Jaunpur		
Water Source	RO Water	Sample No.	Sample 1		
Quality of Sample	1000ml (Normal)	Date of S.C.	17.07.23		
Receiving Date	17.07.2023	S. Collector	Mr Vikhyat Singh		
Sample Depositor	Mr Vikhyat Singh		Analysis Completion Date	18.07.2023	
Analysis Start Date	18.07.2023				
Technical Data of Analysis					
1	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
2	3	4	5	6	
1	pH	7.31	6.5-8.5	6.5-8.5	IS 3025 (Part II): 1983:2021(Electrometric Method)
2	Turbidity (NTU)	0.59	1.00	5.00	IS 3025 (Part 10): 1984:2021(Nephelometer Method)
3	TDS. mg/l	223	500	2000	IS 3025 (Part 16): 1984:2021(Gravimetric Method)
4	Chloride (as Cl), mg/l	10	250	1000	IS 3025 (Part 32): 1988:2021(Titration Method)
5	Total Alkalinity (as Na ₂ CO ₃), mg/l	188	200	600	IS 3025 (Part 23): 1986:2021(Titration Method)
6	Total Hardness (as CaCO ₃), mg/l	92	200	600	IS 3025 (Part 21): 2009:2021(Titration Method)
7	Calcium (as Ca), mg/l	16.8	75	200	IS 3025 (Part 40): 2019
8	Magnesium (as Mg), mg/l	12.5	30	100	IS 3025 (Part 46): 2019
9	Nitrate (as NO ₃), mg/l	5	45	No Relaxation	APHA 23 RD Ed 2017, 4500-NO ₃ (B. Ultraviolet Spectrophotometric Screening Method)
10	Fluoride (as F), mg/l	0.324	1.0	1.5	APHA 23 RD Ed 2017, 4500-F (C. Ion Selection Electrode Method)
11	Iron (as Fe), mg/l	1.00	1.0	No Relaxation	APHA 23 RD Ed 2017, 3500-Fe (B Phenanthroline Method)
12	Residual Chlorine	0.2	NA	0.2	IS 3025 (Part 26): 2021
13	Total Coliform (MPN/100mL)	0	NA	0.0	IS 1622
Note					
1. This Certificate refers only to the particular sample(s) submitted for testing.					
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.					
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.					
4. Sample will be stored up to 15 days (in case of non-perishable items only) from the date of issue of tests reports unless otherwise specified.					
<p><i>Kumra Mohit</i> Prepared by Lab Technician</p> <p><i>RH</i> अधिसासी अभियन्ता खण्ड कार्यालय उत्तर प्रदेश जल नियम (गामोण) जाँपुर</p> <p><i>202</i> Authorized Signatory Quality Technical Manager</p>					

[Signature]
PRINCIPAL
MOUNT LITERA ZEE SCHOOL
FATEHGANJ, JAUNPUR

[Signature]
Director
Mount Litera Zee School
Fatehganj, Jaunpur